



## ***Memorandum***

---

**DATE:** 1-14-2004  
**TO:** Scot McClure  
**FROM:** Nick Veverka  
**RE:** Comments, 1<sup>st</sup> Draft Illinois Distributed Generation Rules

Revisions were made to the original documents reflecting the comments received from Alan Rutkowski, Russ Miller, Mike Goater, and me. Additional General comments on the documents are listed by author below.

Russ Miller - This is very hard to read the sentences are very long and it would be better to make more bullets than to run it on. Also things seem to be organized rather randomly and they could be moved to put common items together.

This only mentions IEEE 1547 as the sole guideline but later under commissioning and testing it conflicts with 1547. Also 1547 is very very general and until more operation guides are written it is not very good.

One thing I did notice is with the various limits on percentage of load and change in fault currents etc we would be limiting this to pretty small units for our area.

Mike Goater - Agreement's Facility Schedule is not well laid out for listing multiple facilities.

### Attachments:

DG Rule - Workshop Draft 1AE.doc  
Distributed Generation Rule - Appendices B and C AE.doc  
Distributed Generation Rule - Appendix A AE.doc